pISSN 2508-1888

eISSN 2466-2461

<http://dx.doi.org/10.14407/jrpr.2016.41.2.117>

Journal of Radiation Protection and Research

Paper

Received July 17, 2015 / 1st Revised May 11, 2016 / Accepted June 7, 2016

Initiating Events Study of the First Extraction Cycle Process in a Model Reprocessing Plant

Renze Wang, Jiangang Zhang, Dajie Zhuang, and Zongyang Feng
China Institute for Radiation Protection, Taiyuan, China

ABSTRACT

Background: Definition and grouping of initiating events (IEs) are important basics for probabilistic safety assessment (PSA). An IE in a spent fuel reprocessing plant (SFRP) is an event that probably leads to the release of dangerous material to jeopardize workers, public and environment. The main difference between SFRPs and nuclear power plants (NPPs) is that hazard materials spread diffusely in a SFRP and radioactive material is just one kind of hazard material.

Materials and Methods: Since the research on IEs for NPPs is in-depth around the world, there are several general methods to identify IEs: reference of lists in existence, review of experience feedback, qualitative analysis method, and deductive analysis method. While failure mode and effect analysis (FMEA) is an important qualitative analysis method, master logic diagram (MLD) method is the deductive analysis method. IE identification in SFRPs should be consulted with the experience of NPPs, however the differences between SFRPs and NPPs should be considered seriously.

Results and Discussion: The plutonium uranium reduction extraction (Purex) process is adopted by the technics in a model reprocessing plant. The first extraction cycle (FEC) is the pivotal process in the Purex process. Whether the FEC can function safely and steadily would directly influence the production process of the whole plant-production quality. Important facilities of the FEC are installed in the equipment cells (ECs). In this work, IEs in the FEC process were identified and categorized by FMEA and MLD two methods, based on the fact that ECs are containments in the plant.

Conclusion: The results show that only two ECs in the FEC do not need to be concerned particularly with safety problems, and criticality, fire and red oil explosion are IEs which should be emphatically analyzed. The results are accordant with the references.

Keywords: IE, PSA, Reprocessing, FMEA, MLD

Correspondence to Renze Wang
wrz198351@163.com

This is an Open-Access article distributed under the terms of the Creative Commons Attribution Non-Commercial License (<http://creativecommons.org/licenses/by-nc/3.0>) which permits unrestricted non-commercial use, distribution, and reproduction in any medium, provided the original work is properly cited.

1. INTRODUCTION

China aspires after spent fuel reprocessing with the rapid development of its nuclear industry. Hence the research on reprocessing plants becomes more and more important in China. Meanwhile, probabilistic safety assessment (PSA) has been a requisite methodology for safety analysis and design amelioration of nuclear facilities. In several countries such as UK, France and Japan PSA for nuclear fuel cycle facilities especially for reprocessing plants have been developed. The International Atomic Energy Agency (IAEA) issued a technical document [1] for conducting PSA for non-reactor nuclear facilities.

Definition and grouping of initiating events (IEs) are not only important steps to PSA analysis but also research basis of the entire level 1 PSA for nuclear power plants (NPPs). IAEA defined an IE in a NPP [2] as that “an IE is an event that creates a disturbance in the plant and has the potential to lead to core damage, depending on the successful operation of the various mitigating systems in the plant”. However, for a spent fuel reprocessing plant (SFRP), an IE is an event that probably leads to the release of dangerous material jeopardizing workers, public and environment. This is because differences exist between NPPs and SFRPs (see Table 1).

Since the research on IEs for NPPs is in-depth around the world, several general methods to identify IEs are shown as follows.

- Reference of lists in existence;
- Review of experience feedback;
- Qualitative analysis method such as failure mode and effect analysis (FMEA) and hazard and operability analysis (HAZOP);
- Deductive analysis method such as master logic diagram (MLD).

IE identification in SFRPs should consult the experience of NPPs and consider the differences. The FMEA and MLD methods were applied to identify initial events of the first extraction cycle (FEC) in a representative spent fuel reprocessing facility adopting

the plutonium uranium reduction extraction (Purex) process. Then initial events were categorized based on the characteristics in a SFRP.

2. MATERIALS AND METHODS

2.1 Study survey of IEs in SFRPs around the world

UK, France and Japan are the representative countries to research IEs in SFRPs around the world. British Nuclear Fuel plc (BNFL) adopted HAZOP means to identify IEs in the PSA to the Thermal Oxide Reprocessing Plant (THORP) located at Sellafield Site [3-8]. BNFL carried out HAZOP in two stages, HAZOP I and HAZOP II. The HAZOP I examined the plant area by area to identify potential generic fault conditions. The HAZOP II is a detailed rigorous examination of each line, vessel and instrument for potential fault conditions.

The Compagnie Générale des Matières Nucléaires (COGEMA) and the Institut de Radioprotection et de Sécurité Nucléaire (IRSN) identified IEs by review of experience feedback during conducting PSA for the UP3-A SFRP [9]. Japan Nuclear Cycle Development Institute (JNC) adopted two qualitative analysis methods, FMEA and HAZOP in the PSA for the Tokai Reprocessing Plant (TRP) [10]. The JNC selected twenty processes from the TRP according to the following viewpoints:

- Amount of radioactive material;
- Existence of the flammable material;
- Necessity of criticality control.

Then the JNC identified IEs in the TRP.

2.2 IE Identification in the FEC

2.2.1 Introduction of the model plant

In 1983, the Chinese central government made the strategy for the integrity of Chinese nuclear industry that reprocessing must be developed corresponding to the development of nuclear power. After 15 years of design and verification the project of the model re-

Table 1. Main Differences between Nuclear Power Plants and Spent Fuel Reprocessing Plants

Item	Nuclear power plants	Spent fuel reprocessing plants
Distribution of hazardous sources	Assemblage in reactor core and spent fuel pool	Spread in storage and process equipment of hazardous resource
Type of hazardous sources	Radioactive material	Radioactive, fissionable, incendive, explosive, poisonous material
Physical state	Mostly solid and liquid	Including solid, liquid and gas, and states are changeful

Corresponding author : Renze Wang, wrz198351@163.com
102 Xuefu Street, Taiyuan, China

Table 2. Equipment Cells in the First Extraction Cycle

Name of Equipment cell	No.
Pulsed columns of collective decontamination equipment cell	R1
Collective decontamination equipment cell	R2
Solvent recycle equipment cell	R3
MLRLW receipt equipment cell	R4
MLRLW condensing equipment cell 1	R5
MLRLW condensing equipment cell 2	R6
Evaporation waste gas disposal equipment cell	R7

processing plant of China (MRPC) was started in 1998. The MRPC adopts the Purex process. The MRPC formally received the first batch of spent fuel of China in September 2003. The construction of the MRPC was basically finished in December 2005. The MRPC succeeded in hot debugging in December 12, 2010.

2.2.2 Introduction of the FEC

The FEC is the pivotal process in the Purex process [11, 12]. Whether this process can function safely and steadily would directly influence the production process of the whole plant-production quality, harvest rate of metal and radiation safety of the whole plant building. Important facilities of the FEC are installed in the ECs shown in Table 2. The following functions should be accomplished in this process under the condition of nuclear safety.

- Collective decontamination and separation cycle: Collective decontamination of uranium and plutonium i.e. primary separation of uranium, plutonium and fission fragments is performed after receipt the feed liquid mixed up in the shearing and dissolution process;
- Solvent recycle: Regenerate of contaminated organic solvent produced in the process.
- Disposal of Medium level radioactive liquid waste (MLRLW): Receive liquid waste from everyday production, examination and maintenance, then evaporate and concentrate the liquid waste.

2.2.3 IE Identification

2.2.3.1 Qualitative analysis

FMEA has been adopted as a qualitative analysis method in this study. FMEA was first applied for fault analysis to the plane motor in U.S. in 1957. FMEA generally includes the following 4 aspects:

- Obtain a better understanding of the object system;

- Analyse fault types and causes of the systemic components;
- Analyse effects of various faults to components and the system;
- Summarize results and propose correctional measures.

Important facilities in the FEC are pulsed columns, mixer-settler and tanks. The following items have been considered in the FMEA analysis:

- Criticality of solution in the equipment is considered as an IE if the content of heavy metal is high;
- Fire of the equipment is considered as an IE when there are much organics and the radioactive activity is greater than or equal to 10^4 MBq in the equipment;
- Incident of equipment erosion is not considered as an IE when the radioactive activity is less than 10^5 MBq in the equipment.

The FMEA results show that there are several IEs—criticality, fire, erosion, red oil explosion, filter core failure and function failure. The idiographic results were not proposed here for conciseness.

2.2.3.2 Deductive analysis

MLD method has been adopted as a deductive analysis method in this study. As a logical tool to deduce qualitative relations between object events and IEs, MLD can be considered as a high level fault tree. The object event of the complete MLD for a NPP is large release of radioactive material or core melt. However, the object event of the MLD for the MRPC is the release of hazardous material as discussed in the introduction. For the FEC, since there are no arresting incensive, explosive and poisonous material, all accidents would lead to radioactivity exceeding the limit, the object event of the MLD for the process is defined as radioactivity exceeding the limit. The MLD was determined according to assessment analysis for equipment in the process (see Figure 1).

2.2.3.3 Summation of IE identification

FMEA and MLD were adopted in this study to identify IEs. The above two methods combine, complement and validate each other, so consistent results were obtained, further analysis could be made based on this research.

2.2.3.4 IE grouping

The purpose of IE grouping is to reduce quantity of PSA for facilities, i.e. reduce the workload. The main

Fig. 1. 52 IEs of four types including criticality, fire, equipment erosion and red oil explosion identified by MLD for the FEC.

principles for IE grouping are two points: First, success criteria for the correlative front systems of IEs in a group are identical; Second, protective and mitigable measures of protective systems for these events are basically identical. IEs, accident sequences and final states of a SFRP are relatively simple. However, characters of a SFRP are distinct and present the tendency of diversification. Therefore grouping of multi-IEs is difficult [13]. This work reckons that existence of ECs are intrinsic conditions for the IE grouping. Because an EC is also safety containment, basically, IEs of the same type in the same EC can be categorized in a group. The results of IE grouping were not proposed here for conciseness.

3. RESULTS AND DISCUSSION

The results of this study show that types of IEs of the FEC in the MRPC include criticality, fire, equipment erosion and red oil explosion. There are 52 IEs identified in total. IEs with severe consequences are shown in Table 3. Based on the facts that important facilities are in

Table 3. Equipment Cells with Severe Consequences

Type	Initiating event count	Equipment cell
Criticality	12	R1, R2
Fire	11	R1, R2, R3
Red oil explosion	2	R5, R6

Table 4. Initiating Events Groups with Severe Consequences

No.	Initiating event name
G1	R1 criticality
G2	R2 criticality
G3	R1 fire
G4	R2 fire
G5	R3 fire
G10	R5 radioactivity leak
G11	R6 radioactivity leak

stalled in ECs in the MRPC, IEs are categorized. IE-groups with severe consequences are shown in Table 4.

Tables 8 and 9 show that only two ECs (R4 and R7) in the FEC do not need to be concerned particularly with safety problems while the other five ECs should be concerned. Safety systems should be enhanced, and operation-regulation systems should be consummated to prevent accidents or to mitigate the consequences of

accidents.

4. CONCLUSION

FMEA and MLD were applied to identify IEs of the FEC in the MRPC by referring to correlative research reports of other SFRPs around the world and considering characters of the MRPC.

Since IE grouping principal for a NPP is not practical for a SFRP, application of the principal is difficult to group IEs rationally and effectively for a SFRP. Considering that the difference between NPPs and SFRPs is that there are ECs in a SFRP, IE grouping principal for a SFRP was proposed: IEs of the same type in the same EC can be categorized in a group. Then, the grouping principal was applied to group IEs of the FEC in the MRPC. The results show that the grouping principal is advanced in logic simplicity and maneuverability, so the grouping principal can be applied for all production processes in a SFRP.

Based on the study in this work, PSA including fault tree and event tree analysis to the FEC in the MRPC is continued.

ACKNOWLEDGMENT

The author would like to acknowledge Dr. Guoqing ZHANG, who is my schoolfellow and obtained a Ph.D. at Karlsruhe Institute of Technology in German, for his help to improve the English expression of the article.

REFERENCES

1. International Atomic Energy Agency. Procedures for conducting probabilistic safety assessment for non-reactor nuclear facilities. IAEA-TECDOC-1267. 2002;1-10.
2. International Atomic Energy Agency. Procedures for conducting probabilistic safety assessments of nuclear power plants (Level 1). Safety Series No. 50-P-4. 1992;28-30.
3. Walls SJ. Applications of probabilistic risk assessment at BNFL, Sellafield. The International Topical Meeting on Safety Margins in Criticality Safety. La Grange Park USA. November 26-December 1, 1989.
4. Bowers WJ. Probabilistic risks assessment applied to nuclear chemical and waste management plants. Czechoslovak-British Nuclear Power Seminar. Prague Czechoslovakia. November 8-9, 1988.
5. Sheppard GT, Taylor JB. The safety case for the thermal oxide reprocessing plant at Sellafield. Technical Committee Meeting of Use of Probabilistic Safety Assessment for Nuclear Installations with Large Inventory of Radioactive Material. Vienna Austria. September 7-11, 1992.
6. Sunman CRJ, Campbell RJ, and Wakem MJ. Probabilistic risk assessment for back-end facilities: improving the treatment of fire and explosion scenarios. The First NUCEF International Symposium. Hitachinaka Japan. October 16-17, 1995.
7. Sheppard GT, Williams RJ. PSA experience with fuel cycle plant. Nucl. Energy. 1993;32(6):363-367.
8. Bowers WJ, Clemson PD, Page RJ. Recent developments in the safety assessment of nuclear chemical plants. The Third International Conference on Nuclear Fuel Reprocessing and Waste Management, RECOD'91. Tokyo Japan. April 14-18, 1991.
9. Mercier JP, Bonneval F, Weber M. Application of the probabilistic approach to the UP3-A reprocessing plant. Technical Committee Meeting of Use of Probabilistic Safety Assessment for Nuclear Installations with Large Inventory of Radioactive Material. Vienna Austria. September 7-11, 1992.
10. Ishida M, Nakano T, Morimoto K, and Nojiri I. PSA application on the Tokai reprocessing plant. The 11th International Conference on Nuclear Engineering. Tokyo Japan. April 20-23, 2003.
11. Ren FY, Zhou ZX. Foreign nuclear fuel reprocessing. 1st ed. Beijing. Atomic Energy Press. 2006;106-173.
12. Jiang SJ, Ren FY. Nuclear fuel reprocessing engineering science. 1st ed. Beijing. Atomic Energy Press. 1995;158-196.
13. Zheng H, Zhao B, Li RR. Primary research of probabilistic safety assessment for spent fuel plant. Nuclear engineering study and design. 2008; 69:30-36.